



1 FOUNDATION PLAN  
3/16" = 1'-0"

- NOTES:
1. TOP OF SLAB EL. = 0'-0"
  2. 4" CONCRETE SLAB, REINFORCED W/ 6x6 - W2 1xW2.1 WWR ON 10 MIL VAPOR RETARDER ON 4" STONE BASE ON GRADE (TYP.)
  3. C.J. DENOTES CONTROL JOINT OR CONSTRUCTION JOINT; REFER TO DETAIL ON S200.
  4. F# DENOTES FOOTING TYPE; REFER TO SCHEDULE THIS SHEET.
  5. BP# DENOTES BASE PLATE; REFER TO 7/S200.
  6. SW# DENOTES SHEARWALL; REFER TO SCHEDULE ON S202
  7. TOP OF FOOTING EL. = -2'-2" @ EXTERIOR U.N.O.
  8. SLEEVE FOOTING AS REQUIRED FOR PIPING PER DETAIL 3/S200. REF MEP FOR PIPE LOCATIONS.

FOOTING (F#) SCHEDULE

MARK	LENGTH	WIDTH	THICKNESS	REINFORCING
F5.0	5'-0"	5'-0"	12	(5) #5 E.W., BOTT
F7.0	7'-0"	7'-0"	14"	(7) #5 E.W., BOTT.
F5.0x13.0	13'-0"	5'-0"	16"	(13) #5 SHORT, (5) #7 LONG, TOP & BOTT

8813 PENROSE LANE, SUITE 400 • LENEXA, KS 66219  
ph: 913.649.8181 • fx: 913.649.1275 • www.hcklover.net

THIS DRAWING has been prepared by the Architect, or prepared under his direct supervision as an instrument of service and is intended for use only on this project. All Drawings, Specifications, ideas and designs, including the overall layout, form, arrangement, and composition of spaces and elements portrayed, constitute the original, unpublished work of the Architect. Any reproduction, use, or disclosure of the information contained herein without the written consent of the Architect is strictly prohibited.

© 2021 H.C. HCKLOVER ARCHITECT

THE ARCHITECT DISCLAIMS responsibility for the existing building structure, site conditions, existing construction elements, or any documents, drawings or other instruments, past or present, of this Project which do not bear the Architect's seal. The Architect's services are undertaken only in the interest of the Project Owner. No obligation is assumed by the Architect for the benefit of any other entity.

RELATED DOCUMENTS: This Drawing is a single component of an integrated set of Construction Documents. General and Supplementary Conditions of the Contract, General Requirements, Specifications and other drawings may affect the Work described. Failure to review and integrate the design intent of the whole of the Construction Documents does not relieve the Contractor from providing a complete Project.

COMPLY WITH all laws, codes, ordinances and regulations with authorities having jurisdiction and with requirements of the Landlord, if applicable. Do not start Work until all permits and required approvals are obtained.

VERIFY ACTUAL CONDITIONS and dimensions prior to construction. Commencement of work constitutes verification and acceptance of all existing conditions. Application of a material or equipment item to Work installed by others constitutes acceptance of that Work and assumption of responsibility for satisfactory installation.

DIMENSIONS SHOWN are to finish face of a material unless otherwise indicated. CALCULATE & RECORD dimensions - DO NOT SCALE drawings unless otherwise directed.

project title

project number  
20045.003

drawing issuance  
PERMIT/BID SET 6.1.2021

drawing revisions  
No. Description Date:

professional seal

BRITT PETERS AND ASSOCIATES INC.  
consulting engineers  
101 Falls Park Drive  
Suite 601  
Greenville, SC 29601  
(864) 271-8869  
(864) 233-5140 Fax  
www.brittpeters.com  
BPA Job No. 210395

drawing number  
S100