

REVISIONS:

ISSUE DATE:

60% SET	11-23-20
90% SET	04-23-20
100% SET	07-09-20
BID SET(CIVIL ONLY)	07-22-20

DRAWN BY: KBS/JM/EH

PANDA PROJECT #: D8086
PANDA STORE #:
CIVIL PROJECT #: 200061



PANDA EXPRESS

TRUE WARM & WELCOME 2300
34898 EMERALD COAST PARKWAY
DESTIN, FLORIDA 32541

PROFILES I

C04.7


SHEET 17 OF 32

TRUE WARM & WELCOME 2200

PROFILE NOTES

- CONTROLLED BACK FILL IN PLACE D8 IN 6" LOOSE LIFT AND COMPACTED TO 100% ASTM D698 PRIOR TO STORM DRAIN INSTALLATION. ALL STORM DRAIN INSTALLATION SHALL BE PLACED TO A MINIMUM OF 2' ABOVE THE CROWN ELEVATION OF THE PIPES.
- STORM DRAIN AND SANITARY SEWER LENGTHS ARE MEASURED FROM CENTER LINE OF STRUCTURE CENTERLINE OF STRUCTURE OR FACE OF HEADWALL. ALL STRUCTURE LENGTHS SHOWN ARE ROUNDED TO THE NEAREST FOOT.
- ALL STORM DRAIN PIPING SHALL BE TRENCHED, BEDDED AND BACKFILLED TO THE TOP OF THE STORM DRAIN SHEET C04.1 UNLESS SPECIFICALLY NOTED OTHERWISE.
- ALL SANITARY SEWER PIPING SHALL BE TRENCHED, BEDDED AND BACKFILLED TO THE TOP OF THE STORM DRAIN SHEET C04.1 UNLESS SPECIFICALLY NOTED OTHERWISE.
- UNFORESEEN SUBSURFACE CONDITIONS SHALL BE BROUGHT TO THE OWNERS AND ENGINEERS ATTENTION IMMEDIATELY. THE CONTRACTOR SHALL TAKE ADDITIONAL MEASURES WITHOUT THE OWNER'S APPROVAL SHALL BE AT THE CONTRACTOR'S OWN RISK AND AT NO ADDITIONAL COST TO THE OWNER.
- EXISTING GRADES SHOWN ARE APPROXIMATE AND DO NOT REFLECT TOP SOIL REMOVAL, CLEARING, AND GRADING OPERATIONS. THE CONTRACTOR SHALL ASCERTAIN FOR HIMSELF THE EXTENT OF DISTURBANCE FOR THESE ACTIVITIES.
- THE CONTRACTOR SHALL REFERENCE THE GEOTECHNICAL REPORT PREPARED FOR THE OWNER FOR SUBSURFACE CONDITIONS. THE GEOTECHNICAL REPORT IS NOT PART OF THE CONTRACT DOCUMENTS.
- EXCAVATIONS FOR STRUCTURES SHALL BE TAKEN AS A TRENCHING EXCAVATION WITHOUT FURTHER CONSIDERATION.
- SEE SHEET C01.1 FOR GENERAL NOTES.

SANITARY PROFILE ES1-S7



SANITARY PROFILE S3-S3.5

